

# PUBLIC HEARING NOTICE

**DATE:** May 29, 2019  
**TIME:** 7:00 P.M.  
**PLACE:** Marshall Township Municipal Building  
525 Pleasant Hill Road (Lower Level)

## DESCRIPTION OFFICIAL NOTICE

Appeal #01– T-Bones, Inc./Thomas Weir is seeking the following: relief from the Marshall Township Uniform Construction Code:

- Relief from the requirement that dispensing devices be located ten (10) feet or more from building having combustible exterior wall surfaces or buildings having noncombustible exterior wall surfaces that are not part of a 1-hour fire resistance rated assembly or buildings having combustible overhangs [International Fire Code Section 2203.1.2.];
- Relief from the requirement that dispensing devices installed outside at motor fuel dispensing stations shall be located as follows ... 3 M (10) feet or more from buildings, other than canopies, having combustible exterior wall surfaces or buildings having noncombustible exterior wall surfaces that are not a part of a 1-hour fire-resistant assembly [National Fire Protection Act 30A Section 6.2.1.2.];
- Relief from the Marshall Township Uniform Construction Code, which incorporates the International Fire Code and the National Fire Protection Act are incorporated into the Uniform Construction Code, Marshall Township Code of Ordinances Chapter 52-2 and 52-3

This application is for property located at 100 VIP Drive, Wexford, PA 15090.

The public is invited to attend.

**MARSHALL TOWNSHIP  
UCC Board**

*FOR INFORMATION PHONE: 724-935-3090*